

13 May 2015

43-47 Newton Rd
Wetherill Park NSW 2164

Tridonic Australia Pty Ltd.

Attention: Phillip Lowe
Dear Sir / Madam,

APPROVAL OF NON-PRESCRIBED EQUIPMENT

Enclosed is the Certificate(s) in respect to your recent application received by Energy Safe Victoria.

Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact Naveen Kapoor on telephone 92039774, or email nkapoor@esv.vic.gov.au

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Energy Safe Victoria of any change of registered Address within 20 business days.

Yours faithfully

A handwritten signature in black ink, appearing to read "P. Lowe".

DIRECTOR OF ENERGY SAFETY

Ref: ESV150300/00

Certificate Number: ESV150300/00



Certificate of Compliance



This is to certify that the Director of Energy Safety has approved the electrical equipment described hereunder.

Registered Declarant: Tridonic Australia Pty Ltd.
43-47 Newton Rd
Wetherill Park NSW 2164

Authorised Marking: ESV150300

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, may be clearly and indelibly marked with the marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification should be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

ARTICLE DETAILS

Electrical Equipment:	Non Prescribed NP: Non-Prescribed dimming LED driver for inbuilding
Relevant Standards:	AS/NZS 61347.2.13:2006; AS/NZS 61347.1:2002
Expiry Date:	13 May 2020
Conditions of Approval:	

A handwritten signature in blue ink, appearing to read "P. J. Flewton".



Certificate Number: ESV150300/00



Approval details

dimming LED driver for inbuilding

Model	LCA 50W 100-400mA one4all lp PRE
Rated at	Input: 220-240 V, 57 W, 50/60 Hz Output: 50-140 Vdc, 14-50 W, 100-400 mA
Trade Name	TRIDONIC
Comments	

Model	LCA 75W 100-400mA one4all lp PRE
Rated at	Input: 220-240 V, 83 W, 50/60 Hz Output: 110-220 Vdc, 22-75.2 W, 100-400 mA
Trade Name	TRIDONIC
Comments	

Model	LCA 100W 250-700mA one4all lp PRE
Rated at	Input: 220-240 V, 111 W, 50/60 Hz Output: 80-220 Vdc, 55-100 W, 250-700 mA
Trade Name	TRIDONIC
Comments	

A handwritten signature in black ink, appearing to read "P. J. Flewton".